

TABLE 1

## TOTAL NUMBER, OF THE 12 SEQUENTIAL SAMPLES, THAT CONTAINED DETECTABLE LEAD

PAGE #	ADDRESS	BEFORE TAMPING (BASELINE)	~1 DAY AFTER TAMPING	~30 DAYS AFTER TAMPING	≥ 60 DAYS AFTER TAMPING
	SEWER MAIN				
2	Exemption 6	10	4	12	
3	Exemption 6	12	12	9	
4	Exemption 6	12	12	11	
5	Exemption 6	11	12	9	
PAGE #	ADDRESS	BEFORE WORK (BASELINE)	~1 DAY AFTER WORK	~30 DAYS AFTER WORK	≥ 60 DAYS AFTER WORK
	FULL LEAD SERVICE LINE REPLACED				
7	Exemption 6		4	0	
8		12	9		12
9	Exemption 6		11		
10	Exemption 6		12	6	5
PAGE #	ADDRESS	BEFORE WORK (BASELINE)	~1 DAY AFTER WORK	~30 DAYS AFTER WORK	≥ 60 DAYS AFTER WORK
	CITY LEAD SERVICE LINE REPLACED				
12	Exemption 6	n/a	7		
13	Exemption 6	n/a	12	8	
14	Exemption 6	n/a	7	3	
15	Exemption 6	n/a	9		
16	Exemption 6	n/a	2		
17	Exemption 6	n/a	0*		
18	Exemption 6	n/a	2		
19	Exemption 6	n/a	8	0	
20	Exemption 6	n/a	12	10	
21	Exemption 6	n/a	Not sampled	2	
22	Exemption 6	n/a	11	4	
23		n/a	3	0	
24		n/a	6	2	
25		n/a	2	5	
26		n/a	2	0	
27		n/a	8	0	
28		n/a	Not sampled	7	
29		n/a	12	11	
30		n/a	12	12	
31		n/a	c	2	
32		n/a	4	0	
33		n/a	2	6	

\*9 Samples submitted (not 12)

c = Sample was collected from rarely used bathroom tap. Data not included in summary.

d = Internal plumbing made of lead

TABLE 1

PAGE #	ADDRESS	BEFORE WORK (BASELINE)	~1 DAY AFTER WORK	~30 DAYS AFTER WORK	≥ 60 DAYS AFTER WORK
	CITY LEAD SERVICE LINE REPLACED (Cont'd)				
34	Exemption 6	n/a	1		
35		n/a	6	0	
36		n/a	12		
37		n/a	12	11	
38		n/a	12	6	
39		n/a	12	5	
40		n/a	8		
41		n/a	4	1	
42		n/a	12		
43		n/a	7		
44		n/a	0	0	
45		n/a	12	12	
46		n/a	12	11	
47		n/a	2		
48		n/a	11	2	
49		n/a	0		
PAGE #	ADDRESS	BEFORE WORK (BASELINE)	~1 DAY AFTER WORK	~30 DAYS AFTER WORK	≥ 60 DAYS AFTER WORK
	METER VALVE				
51	Exemption 6	n/a	12	1	
52		n/a	2	5	
53		n/a	11	7	
54		n/a	2	4	
55		n/a	12	7	
PAGE #	ADDRESS	BEFORE WORK (BASELINE)	~1 DAY AFTER WORK	~30 DAYS AFTER WORK	≥ 60 DAYS AFTER WORK
	OWNER'S LEAK REPAIRED				
57	Exemption 6	n/a	12		
58		n/a	0	8	

\*9 Samples submitted (not 12)

c = Sample was collected from rarely used bathroom tap. Data not included in summary.

d = Internal plumbing made of lead

TABLE 2

## HIGHEST LEAD LEVEL MEASURED IN ANY OF THE 12 SEQUENTIAL SAMPLES

PAGE #	ADDRESS	BEFORE TAMPING (BASELINE)	~1 DAY AFTER TAMPING	~30 DAYS AFTER TAMPING	≥ 60 DAYS AFTER TAMPING
	SEWER MAIN				
2	Exemption 6	5.8	13	11	
3		15	11	8.6	
4		10	5.1	6.6	
5		10	77	14	
PAGE #	ADDRESS	BEFORE WORK (BASELINE)	~1 DAY AFTER WORK	~30 DAYS AFTER WORK	≥ 60 DAYS AFTER WORK
	FULL LEAD SERVICE LINE REPLACED				
7	Exemption 6	69	<2		
8	d	27	46		28
9		69			
10			16	4.8	2.9
PAGE #	ADDRESS	BEFORE WORK (BASELINE)	~1 DAY AFTER WORK	~30 DAYS AFTER WORK	≥ 60 DAYS AFTER WORK
	CITY LEAD SERVICE LINE REPLACED				
12	Exemption 6	n/a	7		
13		n/a	22	8	
14		n/a	35	5.7	
15		n/a	4.9		
16		n/a	2.4		
17		n/a	<2		
18		n/a	2.8		
19		n/a	6.5	<2	
20		n/a	30	8.7	
21		n/a	Not sampled	3.7	
22		n/a	5	3.1	
23		n/a	3.9	<2	<2
24		n/a	5.2	5.1	
25		n/a	2.5	3.6	<2
26		n/a	14	<2	
27		n/a	2.6	<2	<2
28		n/a	Not sampled	17	13
29		n/a	77	6.5	2.1
30		n/a	72	19	
31		n/a	c	7.5	<2
32		n/a	420 a	<2	
33		n/a	2.9	7.6	

a = Resample &lt;2

b = Resample 2.7

c = Sample was collected from rarely used bathroom tap. Data not included in summary.

d = Internal plumbing made of lead. Maximum level in Liter 2 in all sample sets.

TABLE 2

PAGE #	ADDRESS	BEFORE WORK (BASELINE)	~1 DAY AFTER WORK	~30 DAYS AFTER WORK	≥ 60 DAYS AFTER WORK
	CITY LEAD SERVICE LINE REPLACED (Cont'd)				
34	Exemption 6	n/a	6.6		
35		n/a	5.5	<2	
36		n/a	33		
37		n/a	124	4	
38		n/a	190	3.1	
39		n/a	370 b	4.3	8
40		n/a	11		
41		n/a	2.8	2.3	<2
42		n/a	65		
43		n/a	19		
44		n/a	<2	<2	
45		n/a	65	14	9.8
46		n/a	73	6.8	
47		n/a	17		
48		n/a	6.6	2.2	3.2
49		n/a	<2		
PAGE #	ADDRESS	BEFORE WORK (BASELINE)	~1 DAY AFTER WORK	~30 DAYS AFTER WORK	≥ 60 DAYS AFTER WORK
	METER VALVE				
51	Exemption 6	n/a	40	3.2	8.7
52		n/a	7.5	6	
53		n/a	130	3.2	2.7
54		n/a	3	3.6	
55		n/a	22	7.7	6.1
PAGE #	ADDRESS	BEFORE WORK (BASELINE)	~1 DAY AFTER WORK	~30 DAYS AFTER WORK	≥ 60 DAYS AFTER WORK
	OWNER'S LEAK REPAIRED				
57	Exemption 6	n/a	120		
58		n/a	<2	5.8	

a = Resample &lt;2

b = Resample 2.7

c = Sample was collected from rarely used bathroom tap. Data not included in summary.

d = Internal plumbing made of lead. Maximum level in Liter 2 in all sample sets.

TABLE 3

## LEAD LEVEL MEASURED IN THE (WELL-FLUSHED) 13TH SAMPLE

PAGE #	ADDRESS	BEFORE TAMPING (BASELINE)	~1 DAY AFTER TAMPING	~30 DAYS AFTER TAMPING	≥ 60 DAYS AFTER TAMPING
	SEWER MAIN				
2	Exemption 6	<2	<2	<2	
3		5.1	3.9	<2	
4		<2	<2	<2	
5		2.5	<2	<2	
	ADDRESS	BEFORE WORK (BASELINE)	~1 DAY AFTER WORK	~30 DAYS AFTER WORK	≥ 60 DAYS AFTER WORK
	FULL LEAD SERVICE LINE REPLACED				
7	Exemption 6		<2	<2	
8		3	<2		<2
9			<2		
10			<2	<2	<2
	ADDRESS	BEFORE WORK (BASELINE)	~1 DAY AFTER WORK	~30 DAYS AFTER WORK	≥ 60 DAYS AFTER WORK
	CITY LEAD SERVICE LINE REPLACED				
12	Exemption 6	n/a	<2		
13		n/a	<2	<2	
14		n/a	<2	<2	
15		n/a	<2		
16		n/a	<2		
17		n/a	<2		
18		n/a	9.1		
19		n/a	5.7	<2	
20		n/a	3.4	<2	
21		n/a	Not sampled	<2	
22		n/a	<2	<2	
23		n/a	2.8	<2	<2
24		n/a	<2	<2	
25		n/a	<2	<2	<2
26		n/a	<2	<2	
27		n/a	<2	<2	<2
28		n/a	Not sampled	<2	<2
29		n/a	<2	<2	<2
30		n/a	<2	<2	
31		n/a	c	<2	<2
32		n/a	10	<2	
33		n/a	<2	<2	

c = Sample was collected from rarely used bathroom tap. Data not included in summary.

d = Internal plumbing made of lead.

TABLE 3

	ADDRESS	BEFORE WORK (BASELINE)	~1 DAY AFTER WORK	~30 DAYS AFTER WORK	≥ 60 DAYS AFTER WORK
	<b>CITY LEAD SERVICE LINE REPLACED (Cont'd)</b>				
34	<b>Exemption 6</b>	n/a	<2		
35		n/a	2.5	<2	
36		n/a	14		
37		n/a	2.3	<2	
38		n/a	<2	<2	
39		n/a	5	<2	<2
40		n/a	<2		
41		n/a	<2	<2	<2
42		n/a	8.9		
43		n/a	<2		
44		n/a	<2	<2	
45		n/a	2.6	<2	<2
46		n/a	52*	<2	
47		n/a	6.3		
48		n/a	2.2	<2	2.9
49		n/a	<2		
	ADDRESS	BEFORE WORK (BASELINE)	~1 DAY AFTER WORK	~30 DAYS AFTER WORK	≥ 60 DAYS AFTER WORK
	<b>METER VALVE</b>				
51	<b>Exemption 6</b>		<2	<2	<2
52			<2	2.4	
53			4.2	<2	<2
54			<2	<2	
55			<2	<2	<2
	ADDRESS	BEFORE WORK (BASELINE)	~1 DAY AFTER WORK	~30 DAYS AFTER WORK	≥ 60 DAYS AFTER WORK
	<b>OWNER'S LEAK REPAIRED</b>				
57	<b>Exemption 6</b>	n/a	<2		
58		n/a	<2	<2	<2

c = Sample was collected from rarely used bathroom tap. Data not included in summary.

d = Internal plumbing made of lead.